



# Certificate of Compliance

## FIRE PROTECTION EQUIPMENT

This certificate is issued for the following [name] equipment:

Equipment Model Designations:

Approval Guide Listing Category:

Electrical Signaling  Alarm Signal Initiating Devices  Sprinkler Waterflow, Pressure-Actuated

**Duyar Vana Makina Sanayi ve Ticaret Anonim Sirketi**  
Osmangazi Mah 2653 Sk No.7/1, Kirac-Esenyurt,  
Istanbul, 34522, Turkey

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
3132	2018		

Original Approval Job Identification: PR460568

Approval Granted: 2 August 2021

Related Report: PR458238

Subsequent Revisions:

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)



  
J.E. Marquedant  
VP, Manager - Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike,  
Norwood MA, 02062 USA

2 August 2021

Date





# Certificate of Compliance

Electrical Signaling  Alarm Signal Initiating Devices  Sprinkler Waterflow, Pressure-Actuated

## Model DPS-10

Pressure Switch model DPS-10 used in wet and dry type application sprinkler systems. Adjustable switch and operating pressure range of 4 to 12 psi (28 to 82 kpa)

switch contacts:  
10A@125/250Vac  
2.5A@30Vdc



*Member of the FM Global Group*